

Daniel F. Schrantz
Supervisor
716-792-9613
Roxane Sobocki
Town Clerk
716-792-9614



87 West Main Street
Brocton, New York 14716
Fax: 716-792-9610

TDD 711

**SPECIFICATIONS FOR LATERAL WATER HOOK-UP FROM CURB STOP TO
METER IN HOUSE**

MATERIAL: 3/4" type K soft copper tubing
DEPTH: Minimum of 4 feet, (same depth as curb stop).

Service lines from curb box to meter shall be installed throughout its length if possible, at the expense of the owner.

- All lateral connections must be tested and inspected by the Portland Water Department before backfilling.
- All meters shall be set in basement or convenient point accessible to the district.
- All lateral water lines shall be installed by competent and qualified personal, and all work shall be performed in a manner satisfactory to the District.
- Water lines from well source must be installed on a separate service. Pipes carrying water supplied by the district cannot be cross connected with any other apparatus (well system) which may endanger the quality of the District's water supply.
- Pressure reducing valves required.

FOR ANY QUESTIONS YOU MAY CONTACT:

**Drew Smith
Portland Water Department
716-785-1572**

This institution is an equal opportunity provider, and employer. To file a complaint of discrimination, write: USDA, Director, Office of Civil Rights, 1400 Independence Avenue, S.W., Washington, D.C. 20250-9410 or call (800) 795-3272 (voice) or (202) 720-6382 (TDD).